

SECTION 26 5213

PHOTOLUMINESCENT (Running Man) EXIT SIGNS

This section includes editing notes to assist the user in editing the section to suit project requirements. These notes are included as hidden text, and can be revealed or hidden by one of the following methods:

Microsoft Word 2007: Click the OFFICE button, select WORD OPTIONS, select DISPLAY, then select or deselect the HIDDEN TEXT option.

Microsoft Word (earlier versions): From the pull-down menus select TOOLS, then OPTIONS. Under the tab labeled VIEW, select or deselect the HIDDEN TEXT option.

Corel WordPerfect: From the pull-down menus select VIEW, then select or deselect the HIDDEN TEXT option.

PART 1 GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Photoluminescent (Running Man) exit signs.
- B. Related Sections:
 - 1. Division 01: Administrative, procedural, and temporary work requirements.
 - 2. Section 10 1443 - Photoluminescent Egress Path Markings.
 - 3. Section [] - []: Lighting fixtures.

1.2 REFERENCES

- A. National Fire Protection Association (NFPA) (www.nfpa.org) 101 - Life Safety Code.
- B. Underwriters Laboratories, Inc. (UL) (www.ul.com) - 924 - Standard for Emergency Lighting and Power Equipment.
- C. Underwriters Laboratories of Canada (ULC) www.ulc.ca CAN/ULC-S572-Standard for Photoluminescent and self-luminous exit signs and path marking systems

1.3 QUALITY ASSURANCE

- A. Provide exit signs in accordance with [NFPA 101.] [Building Code.]

1.4 SUBMITTALS

- A. Submittals for Review:
 - 1. Shop Drawings: Indicate exit sign (running man) locations, mounting heights, and attachments.
 - 2. Product Data: Include product description, materials, finishes, and performance characteristics.
 - 3. Samples: One full size exit sign (running man). [Sample will be returned for installation on project.]

1.5 DELIVERY, STORAGE AND HANDLING

- A. Store exit signs (running man) in dry location until installed.

PART 2 PRODUCTS

2.1 MANUFACTURERS

A. Contract Documents are based on products by Jessup Manufacturing Company.
(www.jessupmfg.com)

B. Substitutions: [Under provisions of Division 01.] [Not permitted.]

2.2 MANUFACTURED UNITS

- A. Photoluminescent Exit Signs (running man):
1. Product: Glo Brite Eco Exit P50.
 2. Description:
 - a. Self-contained, not requiring external power supply, absorbing and storing energy from ambient LED, fluorescent, metal halide or mercury vapor light.
 - b. Non-toxic, non-radioactive.
 - c. High-visibility green illumination.
 - d. Listed to ULC-S572.
 3. Mounting type: [Wall.] [Ceiling.] [Projected.] [Stem.] [As indicated in Exit Sign Fixture Schedule at end of Section.] [As indicated on Drawings.]]
 4. Mounting brackets: Manufacturer's standard

**** OR ****

5. Conduit brackets: Manufacturer's standard.
6. Construction: Photoluminescent panel.
7. Frame color: [Aluminum][Acrylic/Aluminum]
8. Directional arrows: Part of sign
9. Sign size: 13" x 7.5" x .075" thick
10. Image-Running Man with and without Arrows
11. Performance characteristics:
 - a. Meet NFPA 101 requirements for internally illuminated exit signs.
 - b. Visible at 50 feet in total darkness.
 - c. Tested by UL; listed to ULC-S572.
 - d. Service life: Minimum 25 years.
 - e. Suitable for floor proximity installation

2.3 ACCESSORIES

- A. Fasteners: Type best suited to application.

PART 3 EXECUTION

3.1 INSTALLATION

- A. Install signs in accordance with manufacturer's instructions and approved Shop Drawings.
- B. Locate signs to conform to [Building Code.] [NFPA 101.]
- C. Set signs plumb, level, and rigid.
- D. Attach signs to supporting construction.

3.2 SCHEDULE

SIGN DESIGNATION	SIGN TYPE	MOUNTING TYPE
ES-1	Double sided	Projected
ES-2	Single sided	Wall
ES-3	Single sided	Ceiling

END OF SECTION