



National Floor Safety Institute
1845 Precinct Line Road, Suite 212
Hurst, TX 76054
Phone: (817) 749-1700
info@nfsi.org

September 8, 2023

Nancy Kierna and Ryan Dunteman
Jessup Manufacturing
P.O. Box 366
McHenry, IL 60050

Dear Nancy Kierna and Ryan Dunteman:

Congratulations! The product listed below is recertified as providing "High-Traction". We completed retesting on September 8, 2023, under the NFSI B101.1 Test Method for Measuring the Wet SCOF of Hard-Surface Walkways and the NFSI B101.3 Test Method for Measuring the Wet DCOF of Hard Surface Walkways and the product met or exceeded our minimum acceptable wet SCOF value of 0.60 and our minimum wet DCOF value of 0.45.

Product Name	Original Certification Date	Current Expiration Date	Average SCOF	Average DCOF
Asphalt Art®	1/3/2011	9/7/2026	0.72	0.45

NFSI Certified Products may only bear the NFSI Certified Logo below. Please let us know if you have any questions. Thank you for supporting the product certification process with the NFSI.



Sincerely,

Russell J. Kendzior
President