

UL Online Certifications Directory

[HomeQuick Guide](#)[Contact Us](#)[UL.com](#)

FWBX.E230912

Exit Signs, Self-luminous and Photoluminescent

[Page Bottom](#)

Exit Signs, Self-luminous and Photoluminescent

[See General Information for Exit Signs, Self-luminous and Photoluminescent](#)

JESSUP MFG CO

E230912

2815 W RTE 120

MCHENRY,IL60050USA

Photoluminescent exit signs, 7000 Series, Models 7001, 7001-B, 7002-B, 7011, 7011-B, 7012-B, 7013, 7013-B, 7014-B, 7021, 7021-B, 7022-B, 7031, 7031-B, 7032-B, 7210, 7211, 7220, 7280, 7310, 7320, rated viewing distance 50 ft, minimum 5 ft-c fluorescent, LED, Mercury Vapor or Metal Halide external illumination. "Suitable for Floor Proximity Installation" or equivalent wording.

PF50 Series, Models 7040-B, 7042-B, 7050-B, 7052-B, 7060-B, 7062-B, 7130-B, 7132-B, 7120-B, 7122-B, rated viewing distance 50 ft, minimum 5 ft-c fluorescent, LED, Mercury Vapor or Metal Halide external illumination. "Suitable for Floor Proximity Installation" or equivalent wording.

Photoluminescent running man signs, 7230-R, 7230-L, 7231-R-A, 7231-L-A, rated viewing distance 50 ft, minimum 5 ft-c fluorescent, Mercury Vapor or Metal Halide external illumination. "Suitable for Floor Proximity Installation" or equivalent wording.

Photoluminescent exit signs, Models PM100 7070-B, PM100 7072-B, PM100 7080-B, PM100 7082-B, PM100 7090-B, PM100 7092-B, PM100 7160-B, PM100 7162-B, PM100 7163-B, PM100 7164-B, PM100 7165-B, PM100 7166-B, PM100 7167-B and PM100 7168-B, rated viewing distance 100 ft, minimum 5 ft-c fluorescent external illumination. "Suitable for Floor Proximity Installation" or equivalent wording.

Photoluminescent Exit Sign, Models 7040-100-B, 7042-100-B, 7050-100-B, 7052-100-B, 7060-100-B, 7062-100-B, 7120-100-B, 7122-100-B, 7130-100-B, 7132-100-B, 7140-100-B and 7142-100-B, rated viewing distance 100 ft, minimum 5 ft-c fluorescent, Mercury Vapor, Metal Halide or LED external illumination "Suitable for Floor Proximity Installation" or equivalent wording.

[Last Updated](#) on 2015-08-29

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2015 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2015 UL LLC".